



CITY OF COSTA MESA

P.O. BOX 1200 • 77 FAIR DRIVE • CALIFORNIA 92628-1200

FROM THE DEPARTMENT OF PUBLIC SERVICES/ENGINEERING DIVISION

July 12, 2013

Costa Mesa Planning Commission
 City of Costa Mesa
 77 Fair Drive
 Costa Mesa, CA 92626

SUBJECT: Tract No. 17509
 LOCATION: 2519 and 2525 Santa Ana Avenue

Dear Commissioners:

Tentative Tract Map No. 17509 as furnished by the Planning Division for review by the Public Services Department consists of a two lot subdivision into eight (8) lots to construct detached single-family units. Tentative Tract Map No. 17509 meets with the approval of the Public Services Department, subject to the following conditions:

1. The Tract shall be developed in full compliance with the State Map Act and the City of Costa Mesa Municipal Code (C.C.M.M.C.), except as authorized by the Costa Mesa City Council and/or Planning Commission. The attention of the Subdivider and his engineer is directed to Section 13-208 through 13-261 inclusive, of the Municipal Code.
2. Two copies of the Final Tract Map shall be submitted to the Engineering Division for checking. Map check fee shall be paid per C.C.M.M.C. Section 13-231.
3. A current copy of the title search shall be submitted to the Engineering Division with the first submittal of the Final Tract Map.
4. Dedicate an ingress/egress easement to the City for emergency and public security vehicles purposes only. Maintenance of easement shall be the sole responsibility of a Homeowners Association formed to conform to Section 13-41 (e) of the C.C.M.M.C.
5. Vehicular and pedestrian access rights to Santa Ana Avenue shall be released and relinquished to the City of Costa Mesa except at approved access locations.
6. Fulfill City of Costa Mesa Drainage Ordinance No. 06-19 requirements prior to Approval of Final Map.
7. Fulfill Drainage Ordinance Fee requirements prior to: Approval of Final Map/Approval of Plans
8. Sewer improvements shall meet the approval of the Costa Mesa Sanitary District; call (949) 645-8400 for information.

9. Water system improvements shall meet the approval of Mesa Consolidated Water District; call (949) 631-1200 for information.
10. At the time of development submit for approval an Offsite Plan to the Engineering Division and Grading Plan to the Building Division that shows Sewer, Water, Existing Parkway Improvements and the limits of work on the site, and hydrology calculations, both prepared by a registered Civil Engineer or Architect. Cross lot drainage shall not occur. Construction Access approval must be obtained prior to Building or Engineering Permits being issued by the City of Costa Mesa. Payment of offsite plan check fee per Section 13-231 of the C.C.M.M.C. and an approved Offsite Plan shall be required prior to Engineering Permits being issued by the City of Costa Mesa.
11. The Subdivider's engineers shall furnish to the Engineering Division a storm runoff study showing existing and proposed facilities and the method of draining this area and tributary areas without exceeding the capacity of any street or drainage facility on-site or off-site to the satisfaction of the City Engineer. This study is to be furnished with the first submittal of the Final Map. Cross lot drainage shall not occur. Ownership and maintenance of the private on-site drainage facilities and parkway culverts and other common areas shall be transferred by the owner to the Homeowner Association to be formed pursuant to C.C.M.M.C. Section 13-41.
12. A Construction Access Permit and deposit of \$730 will be required by City of Costa Mesa, Engineering Division prior to start of any on-site work, necessary during construction for street sweeping and to guarantee replacement costs in case of damage to existing public improvements
13. Maintain the public Right-of-Way in a "wet-down" condition to prevent excessive dust and remove any spillage from the public Right-of-Way by sweeping or sprinkling.
14. Haul routes must be approved by the City of Costa Mesa, Transportation & Engineering Division.
15. Obtain a permit from the City of Costa Mesa, Engineering Division, at the time of development and then construct Portland Concrete Cement (PCC) driveway approach per City of Costa Mesa Standards as shown on the Offsite Plan. Location and dimensions are subject to the approval of the Transportation Services Manager. Americans with Disabilities Act (ADA) compliance is required for all new driveway approaches.
16. The Subdivider shall conduct soil investigations and provide the results to the City of Costa Mesa Engineering and Building Divisions pursuant to Ordinance 97-11 and section 66491 of the Subdivision Map Act.
17. Prior to recordation of a Final Tract Map, the surveyor/engineer preparing the map shall tie the boundary of the map into the Horizontal Control System established by the County Surveyor in a manner described in Subarticle 12, Section 7-9-337 of the Orange County Subdivision Code.
18. Prior to recordation of a Final Tract Map, the surveyor/engineer preparing the map shall submit to the County Surveyor a digital-graphics file of said map in a manner described in Subarticle 12, Section 7-9-337 of the Orange County Subdivision Code.

19. Survey monuments shall be preserved and referenced before construction and replaced after construction, pursuant to Section 8771 of the Business and Profession Code.
20. The elevations shown on all plans shall correspond with Orange County benchmark datum.
21. Prior to recordation of a Final Tract Map, submit required cash deposit or surety bond to guarantee monumentation. Deposit amount to be determined by the City Engineer.
22. Prior to Tract occupancy, the surveyor/engineer shall submit to the City Engineer a Digital Graphic File, reproducible mylar of the recorded Tract Map, and approved off-site plan and seven copies of the recorded Tract Map.

Sincerely,

Handwritten signature of Fariba Fazeli in black ink, consisting of a stylized 'F' and 'Fazeli' written in cursive.

Fariba Fazeli
Interim City Engineer