

**CITY OF COSTA MESA**

P.O. BOX 1200 • 77 FAIR DRIVE • CALIFORNIA 92628-1200

FROM THE DEPARTMENT OF PUBLIC SERVICES/ENGINEERING DIVISION

June 16, 2015

Costa Mesa Planning Commission
City of Costa Mesa
77 Fair Drive
Costa Mesa, CA 92626

SUBJECT: Tract No. 17870
LOCATION: 2366 Orange Avenue

Dear Commissioners:


Tentative Tract Map No. 17870 as furnished by the Planning Division for review by the Public Services Department consists of subdividing parcel into six detached residential units. Tentative Tract Map No. 17870 meets with the approval of the Public Services Department, subject to the following conditions:

1. The Tract shall be developed in full compliance with the State Map Act and the City of Costa Mesa Municipal Code (C.C.M.M.C.), except as authorized by the Costa Mesa City Council and/or Planning Commission. The attention of the Subdivider and his engineer is directed to Section 13-208 through 13-261 inclusive, of the Municipal Code.
2. The Subdivider shall conduct soil investigations and provide the results to the City of Costa Mesa Engineering and Building Divisions pursuant to Ordinance 97-11.
3. Two copies of the Final Tract Map shall be submitted to the Engineering Division for checking. Map check fee shall be paid per C.C.M.M.C. Section 13-231.
4. A current copy of the title search shall be submitted to the Engineering Division with the first submittal of the Final Tract Map.
5. Vehicular and pedestrian access rights to Orange Avenue and Norse Avenue shall be released and relinquished to the City of Costa Mesa except at approved access locations.
6. Obtain a permit from the City of Costa Mesa, Engineering Division, at the time of development and then remove any existing driveways and/or curb depressions that will not be used and replace with full height curb and sidewalk.
7. Obtain a permit from the City of Costa Mesa, Engineering Division, at the time of development and then construct P.C.C. driveway approaches per City of Costa Mesa Standards as shown on the Offsite Plan. Location and dimensions are subject to the approval of the Transportation Services Manager.
8. Obtain a permit from the City of Costa Mesa, Engineering Division, at the time of development and then construct P.C.C. sidewalk per City of Costa Mesa Standards as shown on the Offsite Plan, including four (4) feet clear around obstructions in the sidewalk.

9. Submit for approval to the City of Costa Mesa, Engineering Division, Street Improvement Plans that show Sewer and Water Improvements, prepared by a Civil Engineer.
10. The Subdivider shall submit a cash deposit of \$730 for street sweeping at time of issuance of a Construction Access permit. Full amount of deposit shall be maintained on a monthly basis prior to and during construction until completion of project.
11. Fulfill City of Costa Mesa Drainage Ordinance No. 06-19 requirements prior to approval of Final Tract Map
12. The Subdivider's engineers shall furnish the Engineering Division a storm runoff study showing existing and proposed facilities and the method of draining this area and tributary areas without exceeding the capacity of any street or drainage facility on-site or off-site. This study to be furnished with the first submittal of the Final Tract Map. Cross lot drainage shall not occur unless a drainage easement is obtained from the adjacent property owner(s).
13. Ownership and maintenance of the private on-site drainage facilities and parkway culverts and other common areas shall be transferred by the owner to the Homeowner Association to be formed pursuant to C.C.M.M.C. Section 13-41 (e) and said association shall indemnify and hold harmless the City for any liability arising out of or in any way associated with the connection of the private drainage system with the City's drainage system and shall execute and deliver to the City the standard (indemnity) Hold Harmless Agreement required for such conditions prior to issuance of permits.
14. Sewer improvements shall meet the approval of the Costa Mesa Sanitary District; call (949) 631-1731 for information.
15. Water system improvements shall meet the approval of Mesa Consolidated Water District; call (949) 631-1200 for information.
16. Dedicate easements as needed for public utilities.
17. Prior to recordation of a Final Tract Map, the surveyor/engineer preparing the map shall tie the boundary of the map into the Horizontal Control System established by the County Surveyor in a manner described in Subarticle 12, Section 7-9-337 of the Orange County Subdivision Code.
18. Prior to recordation of a Final Tract Map, the surveyor/engineer preparing the map shall submit to the County Surveyor a digital-graphics file of said map in a manner described in Subarticle 12, Section 7-9-337 of the Orange County Subdivision Code.
19. Survey monuments shall be preserved and referenced before construction and replaced after construction, pursuant to Section 8771 of the Business and Profession Code.
20. The elevations shown on all plans shall be on Orange County benchmark datum.
21. Prior to recordation of a Final Tract Map, submit required cash deposit or surety bond to guarantee monumentation. Deposit amount to be determined by the City Engineer.
22. Prior to occupancy on the Tract, the surveyor/engineer shall submit to the City Engineer a Digital Graphic File, reproducible mylar of the recorded Tract Map, and approved off-site plan and nine copies of the recorded Tract Map.

23. Dedicate a 3-foot public sidewalk easement behind existing right-of-way line on Norse Avenue.

Sincerely,

A handwritten signature in black ink, appearing to read 'Fariba Fazeli', written over the word 'Sincerely,'.

Fariba Fazeli, P. E.
City Engineer

(Engr. 2015/Planning Commission Tract 17870)