



The following shall require the installation of smoke detectors and carbon monoxide alarms with battery backup.

- 1- Replacement of roofing or siding.
- 2- Adding or replacing a deck or porch.
- 3- Installation, alterations or repair of plumbing fixtures, mechanical or electrical systems, which do not result in the removal of interior walls or ceiling finishes exposing the structure.

Battery operated smoke alarm shall be installed at the following location(s) .CRC 314

- 1- In each sleeping room
- 2- Outside each separate sleeping area in the immediate vicinity of the bedroom(s).
- 3- On each additional story including basement(s) and habitable attics.
- 4- In dwelling(s) or dwelling units with split levels and without an intervening door between the adjacent levels, a smoke alarm installed on the upper level shall suffice for the adjacent lower level provided that the lower level is less than one full story below the upper level.

Battery operated carbon monoxide alarm shall be install at the following location(s) CRC 315

- 1- Outside of each separate dwelling unit sleeping area in the immediate vicinity of the bedroom(s)
- 2- On every level of a dwelling unit including basements.

Multiple purpose alarms CRC 315.3.1

Carbon monoxide alarms combined with smoke alarms is allowed as per the manufacturers listing and the office of the State Fire Marshall for smoke alarms.